



Intervention Report

Date of Report: 27/12/2017		Date of Intervention : 28/12/2017	
Engineer's name: François-Joseph			
Station			
Name: Hadera		MUX (CH) : MUX1 C29	
Type of Transmitter: Gap Filler		Output Power: 110W	
Failure information			
Description:	Every few minutes the GapFiler went OFF.		
Solution:	It was really hot inside the station (around 45°C). The air conditioner of the station wasn't working at all. I open for few hours and checked all our equipment, everything was find. I also inform Mashav so they can ask cellcom to fix the air conditionner.		
Material Exchange?	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No If Yes, Type:		
Old Serial Number			
New Serial Number			
Others Information			
Output Power: 110W	Limiter Exciter A: Exciter B:		
MER:	Attenuator Exciter A: Exciter B:		
Remarks:			
Additional Information			
Temperature	Exterior (°C)		
	Interior local (°C)	45°C	
Mains fluctuations	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		
Air cleanness	Yes	Dust inside the building	No
Transmitters on air/Total transmitters			

