



THE STATE OF ISRAEL

MINISTRY OF FINANCE

MINISTRY OF ENERGY

THE WATER AUTHORITY

**THROUGH THE SEA-WATER DESALINATION
INTER-MINISTERIAL TENDER COMMITTEE**

August 19, 2018

All Participants

**Re: Invitation for Pre-Qualification
Desalination Facility at "Sorek Plant B" (200 Million m³/year)**

Addendum No. 3

1. Pursuant to the Invitation for Pre-Qualification issued on April 26th, 2018 and in accordance with the provisions thereof, the attention of all Participants is drawn to the clarifications and answers to questions regarding the Invitation - attached to this Addendum as **Appendix "I"**.
2. In accordance with the provisions of the Invitation, you are kindly requested to acknowledge receipt of this Addendum, no later than 2 days following receipt thereof, by a written notice to the Tender Committee, in the format attached to this Addendum as **Appendix "II"**.

Respectfully Yours,

Yitsik Marmelshtein
Chairman of the Tender Committee

CC: Members of the Tender Committee

APPENDIX "I"
ADDENDUM NO. 3 - August 19, 2018
AMENDMENTS, CLARIFICATIONS AND
MODIFICATIONS TO THE INVITATION FOR
PRE-QUALIFICATION

Invitation for Pre-Qualification			Section
1.	Q:	The Tender Committee was requested to extend the Pre-Qualification Submission Date.	1.6(b), 6.9(a)
	A:	The Pre-Qualification Submissions Date is extended to <u>7 October, 2018</u> .	
2.	Q:	The Tender Committee was requested to reduce the required minimum accumulated production capacity from 150,000 m ³ /day to 130,000 m ³ /day, and to reduce the required minimum production capacity of (at least) one sea-water desalination plant from 100,000 m ³ /day to 50,000 m ³ /day.	5.1.1
	A:	The Tender Committee rejects the request.	
3.	Q:	The Tender Committee was requested to add the following alternative in Section 5.1.1: "...The said referenced desalination plant(s) must have been completed within the past seven (7) Years, have been in operation during the past two (2) Years, and have a demonstrated record, readily available for inspection, of successful performance during the entire commercial operation phase, or, if said referenced desalination plant(s) have, solely due to reasons <u>beyond the control of the Desalination Expert, not been operational for the past two (2) Years, then the desalination plant(s) must: (i) have successfully completed commissioning no later than two (2) years prior to the Pre-Qualification Submission Date, and (ii) be readily available for inspection and operation as of the Pre-Qualification Submission Date...</u> "	5.1.1
	A:	The Tender Committee rejects the request. The Tender Committee hereby clarifies that for purposes of Sections 5.1.1 and 5.3.1, the Tender Committee has a wide discretion as to what will be regarded a "successful performance", mainly focusing on extreme cases of gross failures of design and/or installation/construction.	

APPENDIX "II"
ACKNOWLEDGEMENT OF RECEIPT

Date: _____

To
Mr. Yitsik Marmelshtein
Chairman of the Tender Committee

Co./ Ms. Ravit Bar-On
Coordinator of the Tender Committee
E-mail: RavitB@inbal.co.il

Re: Invitation for Pre-Qualification
Desalination Facility at Sorek Plant B (200 Million m³/year)
Addendum No. 3

Pursuant to the Invitation for Pre-Qualification issued on April 26th, 2018 and in accordance with the provisions thereof, we hereby acknowledge receipt of Addendum No. 3 to the Invitation for Pre-Qualification.

(name of Participant and signature of an authorized representative)

Cc: Adv. Michal Schwartz, Lipa Meir & Co.
E-mail: Michals@lipameir.co.il